



**BUREAU  
VERITAS**

Test order / Report No. BVIPL / STEEL : ML/461/7/2017/6  
Date of Receipt : 06-07-2017

Date : 10-07-2017

Page : 1

**Global Ispaat Limited**

M-18,19 and L- 16,Cuncolim Industrial estate,cuncolim, Salcete, Goa-  
403703

**TEST REPORT ON REINFORCING STEEL**

Source of sample : Sample supplied by the customer  
No of Samples Tested : Three  
Customer's Reference : Letter No. GIL/217/2017-18 dated 04.07.2017  
Date of Test : 10-07-2017  
Project\* : Not furnished  
Clients name\* :  
Brand Name\* : MAGNA TMT  
Conditions of sample : Satisfactory  
Test Method : IS: 1608-2005 (Reaffirmed 2011), IS: 1599-1985 and IS:1786-2008

**PHYSICAL PROPERTIES :**

Sl.No	UIN	Identification*	Nominal Dia* (mm)	Mass (WT.) (kg/m)	0.2% Proof Stress / Yield Stress (N/mm <sup>2</sup> )	U T S (N/mm <sup>2</sup> )	Elongation (%)	Bend Test	Rebend Test
1	17021547	Grade - Fe-550	25	3.873	568	699	16.0	PASSE	PASSE

**Requirements as per IS : 1786 - 2008**

Dia (mm)	Mass (wt.) (Kg/m) (Min.)	Dia (mm)	Mass (wt.) (Kg/m) (Min.)	Grade	0.2% Proof Stress (N/mm <sup>2</sup> ) (Min.)	U T S (N/mm <sup>2</sup> ) (Min.)	Elongation (%) (Min.)
8	0.363	20	2.366	Fe - 415	415	485 or 10% more than Actual Proof Stress whichever is higher	14.5
10	0.567	25	3.697	Fe - 500	500	545 or 8% more than Actual Proof Stress whichever is higher	12.0
12	0.834	28	4.638	Fe - 550	550	585 or 6% more than Actual Proof Stress whichever is higher	10.0
16	1.483	32	6.058	Fe - 550	550	585 or 6% more than Actual Proof Stress whichever is higher	10.0

\* As furnished by the customer

Remarks : The tested samples conforming to IS:1786-2008 requirements for Fe-550 Grade with respect to Physical tests conducted.

Note : 1. The Results relate only to the samples tested  
2. Report shall not be reproduced, except in full, without the written approval of the lab.  
3. Any correction invalidates this report.

for **BUREAU VERITAS (INDIA) PRIVATE LIMITED**  
Construction Services Laboratory

*Soma Raviteja*  
10.07.2017  
**SOMA RAVITEJA**  
Engineer-LAB



Bureau Veritas (India) Private Limited  
(Construction Services Laboratory)  
Shed No. C-27, Industrial Estate  
Yeyyadi, Mangalore - 575 008, India  
Tel.: +91 824 2213571  
lab.mangalore@in.bureauveritas.com

Regd. Off : Marwah Centre, 6th Floor  
K. Marwah Marg, Off Saki-Vihar Road  
Andheri (East), Mumbai - 400 072, India  
Tel.: +91 22 66956300 Fax: +91 22 66956309  
www.bureauveritas.co.in  
CIN : U74210MH2001PTC134262

Offices/Labs at: Ahmedabad, Bangalore  
Baroda, Bhopal, Chennai, Cochin  
Coimbatore, Delhi, Goa, Hubli, Indore  
Jaipur, Kakinada, Kandla, Kolkata  
Ludhiana, Nagpur, Nashik, Pune, Raipur  
Surat, Trichy & Visakhapatnam